



PUBLIC WORKS DEPARTMENT (B & R), HARYANA
Office of Executive Engineer,
Provincial Division, PWD B&R Br., Faridabad.
Tele - 0129-2288187
Email ID: pwd-ccpd1-faridabad@hry.nic.in



Memo No 33/6

Dated 10/06/2022

To

The Principal
Shiva Public Sr. Sec. School
Sikri, Ballabgarh, District Faridabad

Subject:- NOC for building structure safety certificate for Shiva Public Sr. Sec. School, Sikri, Ballabgarh, District Faridabad.

Reference:- Your office letter dated 06.06.2022.

In the connection of above cited subject, it is submitted that the above said school building is inspected by Sh Indraj Singh, Sub Divisional Engineer, Provincial Sub Division No.3, Faridabad alongwith Sh. Siddharth Dev, Junior Engineer of this office on 09.06.2022. The school building having lower ground floor, upper ground floor & first floor. Following are the features of the building observed during the inspection of the school:-

LOWER GROUND FLOOR:-

➤ At lower ground floor there are 10 no. Classrooms, 01 no. Boys toilet & 02 no. Staircases exit in the lower ground floor level.

UPPER GROUND FLOOR:-

➤ At upper ground floor there are 08 no. Classrooms, 01 No. Principal office including 01 no. retiring room and 01 no. toilet, 01 no. Reception /Entrance Hall, 01 no. Staff room, 01 no. Store room, 01 no. Girls toilet, 01 no. Boys toilet and 02 no. Staircases exit in the upper ground floor level.

FIRST FLOOR:-

➤ At first floor level there are 7 no. Classrooms, 01 no. Chemistry Lab, 01 no. Library, 01 no. Girls toilet, 01 no. Boys toilet & 02 no. Staircases exit in the first floor level.

The building is constructed with frame structure having RCC column, beams slab and 9" thick load bearing outer walls. The structure stability certificate has been also enclosed, which issued by Konzept Design Consortium Pvt. Ltd., 389, Ground Floor, IP Colony, Sector-30-33, District Faridabad on dated 22.05.2020. The fire NOC has also been issued to the concern school vide Senior Fire Station Officer in Sector-15A, Faridabad letter No. F.S/2017/F1038/1436 Dated 26.12.2017 valid upto 25.12.2022. The Hygiene Certificate is also issued O/o Civil Surgeon, Faridabad vide letter No.HHC/FBD/2022/000107 dated 29.04.2022. Further NOC has been applied for keeping in view all the circumstance the building of

Shiva Public Sr. Sec. School Sikri, Ballabgarh, District Faridabad is seems to be safe and this office has no objection to give safety certificate with validity of one year i.e 11.09.2023. Periodical inspection must be insured.

DANil



Executive Engineer,
Provincial Division,
PWD (B & R) Br. Faridabad

Endst. No.

Dated .

Copy forwarded to the Sub Divisional Engineer, Provincial Sub Division No. 3 , PWD B&R Br. Faridabad for information and necessary action w.r.t. his office letter memo no. 822 dated 09.06.2022.

DA/ Nil


Executive Engineer,
Provincial Division,
PWD B&R Br. Faridabad